

## BENTON COUNTY ORDINANCE NO. 300

WHEREAS, the Benton County Board of Commissioners instituted proceedings to amend Ordinance 185 as follows; and,

WHEREAS, on April 13, 1999 Notice of Public Hearing and intent to amend Benton County Ordinance 185, Sections 3, 7.3.3(f), 7.4.3(f) and 7.5.3(f) was published in the official newspaper of the county; and,

WHEREAS, on April 29, 1999 the Benton County Planning Commission held a public hearing thereon and recommended to the Benton County Board of Commissioners that said amendments be approved; and,

WHEREAS, on May 4, 1999 the Benton County Board of Commissioners took official action to approve the proposed amendment.

NOW PURSUANT TO THE AUTHORITY VESTED BY MINNESOTA STATUTES SECTION 394.25, THE BENTON COUNTY BOARD OF COMMISSIONERS ORDAINS:

that Benton County Ordinance 185, Sections 3, 7.3.3(f), 7.4.3(f) and 7.5.3(f) as follows:

*Residential Fire Protection Water: a subdivision served with hydrants, piping and necessary infrastructure to deliver 1,000 gallons per minute of water at 20 pounds per square inch pressure at a fire hydrant outlet for fire departments, for fire suppression purposes. The piping, hydrant and infrastructure design must be signed by a licensed engineer, certifying that the water system will deliver the required amount of fire protection water as required by State Standards Ordinances. After the system is constructed, an engineer must certify that the water supply system was constructed per the design requirements and the fire protection water supply system must be tested and an engineer must certify the test results.*

7.3.3(f) add *-Side Yard Abutting Land zoned R-1, R-2, or R-3, where Residential Fire Protection Water is available with a subdivision .... 10 feet minimum.*

7.4.3(f) add *-Side Yard Abutting Land zoned R-1, R-2, or R-3, where Residential Fire Protection Water is available with a subdivision .... 10 feet minimum.*

7.5.3(f) add *-Side Yard Abutting Land zoned R-1, R-2, or R-3, where Residential Fire Protection Water is available with a subdivision .... 10 feet minimum.*


This Ordinance amendment shall be effective upon publication.

4<sup>th</sup> APPROVED AND ADOPTED by the Benton County Board of Commissioners this day of May in the year of 1999.



Ken Neeser, Chair  
Benton County Board of Commissioners

ATTEST:



Rick Speak, Clerk

2 6 3 4 6 2

OFFICE OF  
BENTON COUNTY RECORDER  
BENTON COUNTY, MN  
CERTIFIED TO BE FILED  
AND/OR RECORDED BY

JAN 5 3 22 PM '00

ALICE G. ENGBREYER  
COUNTY RECORDER

BY BW DEPUTY